

VAISHAL PATLIPUTRA DUGDH UTPADAK SAHKARI SANGH LTD
PATNA DAIRY PROJECT

Feeder Balancing Dairy Complex, Phulwarisharif, Patna – 801505
Phone – 0612-2252553, 2252542, 2251622, Fax-2250325
Email :- vpmu.pur@gmail.com

VPDUSS-SOP-8.5.1.2-01.F02

PDP: PUR:FBD: 4121

Dated: 16.04.2024

Dear sir,

We are interested in purchasing of the following item. In case you can supply the same, you may send your quotation in sealed cover addressed to the Managing Director address given above superscribing on the top of the envelop quotation **One Blast Cooling Unit for Paneer at our FBD** so as to reached us on or before **30.04.2024**.


Blast Cooling unit to be Install in Paneer Room with following requirement.

1. Dimension of Blast Room is 9' x 7' x 9' (L*B*H)
2. Block Size of Paneer – 420mm x 320mm x 90mm
3. Temperature of Paneer Bulk before blast Cooling = 20-25°C
4. Required temperature of Paneer after blast Cooling = 5°C to 10°C

Please submit your offer F.O.R. our Dairy including Installation & Commissioning with Price breakup of Basic, Taxes etc.

S.No.	Item	Specification	Qty.required
1	BLAST COOLING UNIT FOR PANEER		01 nos

Thanking you


Manager (MM)